



FP-044B

The Commonwealth of Massachusetts
City of Town of _____



TRANSFER TANK INSPECTION
(Transportation of Combustible Liquids)

REG # _____ **VIN #** _____

NAME OF OWNER _____

527 CMR 1.00: CHAPTER 42 REQUIREMENTS	YES	NO
Permits: FP-044		
The tank is securely mounted to the vehicle body or truck bed and its capacity does not exceed 119 gallons – 527 CMR 1.00: Chapter 42, Section 42.15.2(1)		
The tank shall be constructed of not less than 14 USS gauge standard open hearth steel tank plate or 1/8 inch aluminum – 527 CMR 1.00: Chapter 42, Section 42.15.2(2)		
The liquid is drawn only from the top of the tank by means of a suitable pump to which is attached a durable hose equipped with a self-closing nozzle – 527 CMR 1.00: Chapter 42, Section 42.15.2(3)		
The vehicle is equipped with a fire extinguisher with a minimum rating of 1-A: 10-B,C – 527 CMR 1.00: Chapter 13, Section 13.6		

No cargo tank, portable tank or transfer tank shall be mounted in the bed or body of any vehicle with contains a hoist to raise such bed or body – 527 CMR 1.00: Chapter 42, Section 42.9.8.4

INSPECTED BY: _____

FIRE DEPARTMENT _____

DATE: _____ **PERMIT#** _____

Affix Tank Truck Permit decal to the upper left quadrant of the transport vehicle.